

Government of Jammu and Kashmir
Office of the Chief Engineer, Jal Shakti (I & FC) Department, Jammu
(Tel/Fax-0191-2582164, E-mail: ifcjm@gmail.com Website: www.jkirfc.com)

**The Executive Engineer,
JAKEDA, Science and Technology Department
Jammu**

No:- IFCJ/Works/ 3376-79

Dated:- 24/05/2023


**Subject:- Issuance of NOC for the development of 2.0 MW MHP Muller at Chatroo Nallah
Tehsil Chatroo district Kishtwar under IPP mode of implementation**

**Reference: i) Superintending Engineer Hydraulic Circle Doda No: SE/HCD/2022-23/6041-42
dated: 23-03-2023.**

**ii) Executive Engineer, Hydraulic Division Kishtwar's No: JS/HDK/22-23/
12565-67 Dated: 14-3-2023.**

On the basis of report submitted by Superintending Engineer / Executive Engineer concerned vide their letters cited above on the subject matter, the NOC is hereby granted for the development of 2.0 MW MHP Muller at Chatroo Nallah Tehsil Chatroo district Kishtwar under IPP mode of implementation, subject to the compliance of the following conditions:

1. That the executing agency should abide by all the guidelines and precautions as laid down in the J&K Water Resources (Regulation and Management) Act 2010
2. The Minimum discharge as per provision of NGT Guidelines is to be maintained for use by living creatures (i.e. humans, animals ,aquaculture/aqua life and plants)
3. That the project should not cause any soil erosion in the area which may result destruction of life and property.
4. That the project should not hamper construction of any Irrigation/Flood Projects, if proposed in future on the said area.
5. The proposed Power House and other structures be constructed alongwith suitable Protection works, if required, at site without any reduction of the water way and obstruction of the flow of water course in any manner. There should be no erosion/inundation due to construction of these structures.
6. During the execution of the project , this department shall have free access to the site and shall be provided any equipment /facility required for inspection of works.
7. The Department shall not be responsible for any disruption of operation of Power Plant due to less/insufficient discharge in Nallah or due to any reason thereof.
8. The water usage charges as per J&K Water Resources (Regulation and Management) Act 2010 and Water Resources (Regulation and Management) rules 2011 and notified from time to time by the Authority shall be paid by Project authorities.


(Er. Manoj Gupta)
Chief Engineer,
Irrigation & F.C. Department,
Jammu.

Copy to the:-

1. **Private Secretary to Principal Secretary , Jal Shakti Department Civil Secretariat Jammu for kind information of worthy Principal Secretary .**
2. **Superintending Engineer Hydraulic Circle Doda for information.**
3. **Executive Engineer Hydraulic Division Kishtwar's No: JS/HDK/22-23/12565-67
Dated: 14-3-2023.**